

### **Table of Notifiable Works**

The table below gives a list of the of the most common locations experienced within the home and whether or not the work taking place within these locations requires Part P notification.

A tick means that the work requires Part P notification; a cross indicates that it does not.

Do not forget that the appropriate BS7671 certificate must always be completed.

<b>Domestic Location</b> Where work is being carried out	<b>Minor Works</b> (extensions and modification to circuits)	<b>Major Works</b> (new circuits)
Bathrooms	✓	✓
Bedrooms	x	✓
Bedrooms containing a shower or basin	✓	✓
Ceiling (over head) heating	✓	✓
Communal area of flats	✓	✓
Computer cabling	x	x
Conservatories	x	✓
Dining rooms	x	✓
Extra low voltage (E.L.V.) Non pre-assembled CE marked lights	✓	✓
Garden - lighting	✓	✓
Gardens - power	✓	✓
Greenhouses	✓	✓
Halls	x	✓
Integral garages	x	✓
Kitchen	✓	✓
Kitchen diners	✓	✓
Landings	x	✓
Lounge	x	✓
Remote buildings	x	✓
Remote garages	x	✓
Saunas	✓	✓
Sheds	x	✓
Shower rooms	✓	✓
Small scale generators	✓	✓
Solar power systems	✓	✓
Stairways	x	✓
Studies	x	✓
Swimming pools	✓	✓
Telephone cabling	x	x
TV Rooms	x	✓
Under floor heating	✓	✓
Workshops (remote)	x	✓